



Flammability Granuflex® rubber tiles

Date : March, 2008

Granuflex® rubber tiles have been tested on Flammability.

Time from application of nut to extinction of flame	(s)	270	204	221
Greatest radius of affected area	(mm)	15	15	15

The Flammability results meet the requirement given in BS 5696.

Classification: **LOW** radius of effects of ignition.

Best Regards,

Agnetha Bernardt
Sales Representative
Granuflex®



Siciliëweg 20 • 1045 AS Amsterdam
Tel. 020 - 4978201 • Fax 020 - 4978216
E-mail: info@granuflex.nl
www.granuflex.nl

Granuflex® is een merknaam van Granuband bv • Siciliëweg 20 • 1045 AS Amsterdam Telefoon
020-4978201 • Telefax 020-4978216 • K.v.K. Amsterdam 33232674 sales@granuflex.nl •
www.granuflex.nl

Op al onze aanbiedingen en overeenkomsten zijn van toepassing onze leveringsvoorwaarden, gedeponeerd
bij de K.v.K. te Amsterdam d.d. 9 oktober 1995 onder nr. 4292