




## Wind uplift suitability. Test results from BRE to BS 5534 Annex A – Novia Reflex

100mm taped overlap test results (Taped using Novia Breather Membrane Lap Tape)			
Product	Identification	Manufacturer	Website
Novia Reflex	LR	Novia Ltd	<a href="http://www.novia.co.uk">www.novia.co.uk</a>
Batten Gauge	Declared wind uplift resistance, p D (N/m <sup>2</sup> )	Zone Suitability	Wind zone map
≤ 345 mm	1967	1-5	
≤ 250 mm	No test required	No test required	
≤ 100 mm	No test required	No test required	

150mm overlap batten restraint test results			
Product	Identification	Manufacturer	Website
Novia Reflex	LR	Novia Ltd	<a href="http://www.novia.co.uk">www.novia.co.uk</a>
Batten Gauge	Declared wind uplift resistance, p D (N/m <sup>2</sup> )	Zone Suitability	Wind zone map
≤ 345 mm	975	1-2	
≤ 250 mm	2257	1-5	
≤ 100 mm	No test required	No test required	